

Blank Page 1 of 2

Blank Page 2 of 2

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NELSON ANALYTICAL LAB

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500
 Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:55 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050756.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	007	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	15 FIFTH ST	Comp. Period and Type:	MAY 2020 RT TCR

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
Total Coliform Bacteria	Absent	/100mL	SM 9223B	Absent	Absent	05/08/2020 16:50	NH
E. coli Bacteria	Absent	/100mL	SM 9223B	Absent	Absent	05/08/2020 16:50	NH

Respectfully Submitted



 Andrew Nelson, Laboratory Director


Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt. "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # - Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.
 Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7; Nelson Analytical E4I Div. NH1007, SUB4: NH2073/2239, SUB5: NH2530, SUB8: NH2136, SUB9: NH2557

http://des.nh.gov/organization/divisions/water/dwqb/nhelap/
 http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx
 https://www.maine.gov/dhhs/meedc/environmental-health/dwp/professionals/labCert.shtml
 https://www.mass.gov/certified-laboratories

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200
 NH ELAP Accreditation #NH1005

NELSON ANALYTICAL LAB

Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500
 Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:45 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050759.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	000	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	10 F / FRANK SHULTZ /WELLS 001 002	Comp. Period and Type:	Q2 2020 RT CHEM

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
Fluoride	<0.20	mg/L	SM 4500F-C	0.2	4.0	05/11/2020 14:20	GP
Antimony	<0.002	mg/L	EPA 200.8	0.001	0.004	05/11/2020 12:39	AON
Arsenic	0.003	mg/L	EPA 200.8	0.001	0.010	05/11/2020 12:39	AON
Barium	0.016	mg/L	EPA 200.8	0.001	2.00	05/11/2020 12:39	AON
Beryllium	<0.001	mg/L	EPA 200.8	0.001	0.002	05/11/2020 12:39	AON
Cadmium	<0.001	mg/L	EPA 200.8	0.001	0.005	05/11/2020 12:39	AON
Chromium	0.009	mg/L	EPA 200.8	0.001	0.100	05/11/2020 12:39	AON
Copper	<0.010	mg/L	EPA 200.8	0.01	1.30	05/11/2020 12:39	AON
Lead	<0.001	mg/L	EPA 200.8	0.001	0.015	05/11/2020 12:39	AON
Mercury	<0.0004	mg/L	EPA 200.8	0.0004	0.002	05/11/2020 12:39	AON
Nickel	<0.001	mg/L	EPA 200.8	0.001	0.10	05/11/2020 12:39	AON
Selenium	<0.010	mg/L	EPA 200.8	0.001	0.050	05/11/2020 12:39	AON
Silver	<0.010	mg/L	EPA 200.8	0.01	0.100	05/11/2020 12:39	AON
Thallium	<0.001	mg/L	EPA 200.8	0.001	0.002	05/11/2020 12:39	AON
Zinc	<0.010	mg/L	EPA 200.8	0.01	5.00	05/11/2020 12:39	AON
Iron	0.065	mg/L	EPA 200.8	0.03	0.300	05/11/2020 12:39	AON
Manganese	0.003	mg/L	EPA 200.8	0.001	0.050	05/11/2020 12:39	AON
Chloride	<6	mg/L	SM 4500Cl-B	6	250	05/11/2020 10:05	GP
pH	8.06	SU	SM 4500H B	N/A	6.5-8.5	05/08/2020 17:05	GP
Alkalinity	80	mg/L	SM 2320B	20	N/A	05/11/2020 11:15	GP
Conductance	230	umhos/cm	SM 2510B	25	N/A	05/11/2020 14:40	GP
Sulfate	18	mg/L	SM 4500SO4-E	5	250	05/16/2020 11:30	SUB2
Sodium	17	mg/L	EPA 200.8	1	N/A	05/11/2020 12:39	AON
Total Hardness	106	mg/L	SM 2340B	4	N/A	05/11/2020 12:39	AON
Cyanide	<0.005	mg/L	EPA 335.4	0.005	0.20	05/21/2020 17:00	SUB8

Respectfully Submitted




Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt, "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # -Sample(s) received at laboratory do not meet method specified temperature criteria. Solid samples are reported on a dry weight basis unless noted otherwise.

Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7: Nelson Analytical EAI Div. NH1007, SUB4:NH2073/2239, SUB5:NH2530, SUB8:NH2136, SUB9:NH2557

<http://des.nh.gov/organization/divisions/water/dwgb/nhelap/>
http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx
<https://www.maine.gov/dhhs/meedc/environmental-health/dwp/professionals/labCert.shtm>
<https://www.mass.gov/certified-laboratories>

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NELSON ANALYTICAL LAB

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500
 Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:45 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050757.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	000	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	10 F / FRANK SHULTZ /WELLS 001 002	Comp. Period and Type:	Q2 2020 RT CHEM

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
Nitrate-N	<1.0	mg/L	SM 4500 NO3 D	1	10	05/08/2020 17:00	GP

Respectfully Submitted



Andrew Nelson, Laboratory Director

Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt. "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # -Sample(s) received at laboratory do not meet method specified temperature criteria.



Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7: Nelson Analytical EAI Div, NH1007, SUB4:NH2073/2239, SUB5:NH2530, SUB8:NH2136, SUB9:NH2557

<http://des.nh.gov/organization/divisions/water/dwqb/nhwap/>
http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx
<https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml>
<https://www.mass.gov/certified-laboratories>

490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NELSON ANALYTICAL LAB

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500
 Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:45 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050758.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	000	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	10 F / FRANK SHULTZ / WELLS 001 002	Comp. Period and Type:	Q2 2020 RT CHEM

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
Bromodichloromethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Bromoform	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Chloroform	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Dibromochloromethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Total Trihalomethanes	<2.0	ug/L	EPA 524.2	2.0	80	05/12/2020 13:24	RC
Acetone	<50	ug/L	EPA 524.2	50	NA	05/12/2020 13:24	RC
Benzene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Bromobenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Bromochloromethane	<1.0	ug/L	EPA 524.2	1.0	NA	05/12/2020 13:24	RC
n-Butylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
sec-Butylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Tert-Butylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Carbon disulfide	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Carbon tetrachloride	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Chloroethane	<1.0	ug/L	EPA 524.2	1.0	NA	05/12/2020 13:24	RC
Chloromethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
2-Chlorotoluene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
4-Chlorotoluene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Dibromomethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,2-Dichlorobenzene	<0.5	ug/L	EPA 524.2	0.5	600	05/12/2020 13:24	RC
1,3-Dichlorobenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,4-Dichlorobenzene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Dichlorodifluoromethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,1-Dichloroethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,2-Dichloroethane	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
1,1-Dichloroethylene	<0.5	ug/L	EPA 524.2	0.5	7.0	05/12/2020 13:24	RC
cis-1,2-Dichloroethylene	<0.5	ug/L	EPA 524.2	0.5	70	05/12/2020 13:24	RC
trans-1,2-Dichloroethylene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
1,2-Dichloropropane	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC

Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt. "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. #Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.
 Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2019 SUB 7: Nelson Analytical EAL Div. NH1007, SUB4:NH2073/2239, SUB5:NH2530, SUB8:NH2136, SUB9:NH2557

<http://des.nh.gov/organization/divisions/water/dwgb/nhelap/>
http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx
<https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml>
<https://www.mass.gov/certified-laboratories>



490 East Industrial Park Drive
 Manchester, NH 03109
 www.nelsonanalytical.com
 (603)622-0200

NELSON ANALYTICAL LAB

NH ELAP Accreditation #NH1005
 Maine State Certification #NH01005
 Vermont State Certification # VT1005
 Maine Radon Certification # ME17500
 Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:45 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050758.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	000	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	10 F / FRANK SHULTZ /WELLS 001 002	Comp. Period and Type:	Q2 2020 RT CHEM

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
1,3-Dichloropropane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,1-Dichloropropene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
cis-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
trans-1,3-Dichloropropene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Diethyl Ether	<1.0	ug/L	EPA 524.2	1.0	NA	05/12/2020 13:24	RC
Diisopropyl ether	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Ethyl tert-Butyl Ether	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Hexachlorobutadiene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Isopropylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
4-Isopropyltoluene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Chlorobenzene	<0.5	ug/L	EPA 524.2	0.5	100	05/12/2020 13:24	RC
Ethylbenzene	<0.5	ug/L	EPA 524.2	0.5	700	05/12/2020 13:24	RC
Methylene chloride	<2.4	ug/L	EPA 524.2	2.4	5.0	05/12/2020 13:24	RC
MTBE	<0.5	ug/L	EPA 524.2	0.5	13.0	05/12/2020 13:24	RC
Naphthalene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
n-Propylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
2-Hexanone	<5.0	ug/L	EPA 524.2	5.0	NA	05/12/2020 13:24	RC
Styrene	<0.5	ug/L	EPA 524.2	0.5	100	05/12/2020 13:24	RC
1,1,1,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,1,2,2-Tetrachloroethane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
tert-Amyl Methyl Ether	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
tert-Butyl Alcohol	<50	ug/L	EPA 524.2	50	NA	05/12/2020 13:24	RC
Tetrachloroethylene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Tetrahydrofuran	<10	ug/L	EPA 524.2	10	NA	05/12/2020 13:24	RC
Toluene	<0.5	ug/L	EPA 524.2	0.5	1000	05/12/2020 13:24	RC
1,2,3-trichlorobenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,2,4-Trichlorobenzene	<0.5	ug/L	EPA 524.2	0.5	70.0	05/12/2020 13:24	RC
1,1,1-Trichloroethane	<0.5	ug/L	EPA 524.2	0.5	200	05/12/2020 13:24	RC
1,1,2-Trichloroethane	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC

Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt, "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # -Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.

Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7: Nelson Analytical EAI Div. NH1007, SUB4:NH2073/2239, SUB5:NH2530, SUB8:NH2136, SUB9:NH2557

<http://des.nh.gov/organization/divisions/water/dwgb/nhelap/>

http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx

<https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtm>

<https://www.mass.gov/certified-laboratories>





RP200513056

490 East Industrial Park Drive
Manchester, NH 03109
www.nelsonanalytical.com
(603)622-0200

NELSON ANALYTICAL LAB

NH ELAP Accreditation #NH1005
Maine State Certification #NH01005
Vermont State Certification # VT1005
Maine Radon Certification # ME17500
Massachusetts State Certification #M-NH1005

Report of Analysis

Customer:	Gilford Well Co., Inc.	Date/Time Collected:	05/08/20 12:45 PM
System Name:	Mallards Landing	PWSID:	0203080
Laboratory ID:	120050758.01	Date/Time Received:	05/08/20 4:15 PM
Sample Site ID:	000	Collected By:	M. Saulnier
System Town:	Belmont	Temperature Rec'd °C:	#12.2
Sample Location:	10 F / FRANK SHULTZ /WELLS 001 002	Comp. Period and Type:	Q2 2020 RT CHEM

Parameter	Result	Units	Method	Rpt Limit	Reg. Limit	Date/Time Analyzed	Analyst
Trichloroethylene	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
Trichlorofluoromethane	<0.5	ug/L	EPA 524.2	0.5	5.0	05/12/2020 13:24	RC
1,2,3-Trichloropropane	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
1,2,4-Trimethylbenzene	<5.0	ug/L	EPA 524.2	5.0	NA	05/12/2020 13:24	RC
1,3,5-Trimethylbenzene	<0.5	ug/L	EPA 524.2	0.5	NA	05/12/2020 13:24	RC
Vinyl Chloride	<0.9	ug/L	EPA 524.2	0.9	2.0	05/12/2020 13:24	RC
xylenes (total)	<1.5	ug/L	EPA 524.2	1.5	10,000	05/12/2020 13:24	RC

Respectfully Submitted


Andrew Nelson, Laboratory Director

Notes: mg/L=ppm; ug/L=ppb; ng/L=ppt, "<" denotes "less than". This report of analysis may not be modified in any way, or reproduced except in full, without written approval from Nelson Analytical, LLC. Results reported above relate only to samples as submitted, unless specifically noted otherwise. Nelson Analytical, LLC is currently accredited by the New Hampshire Environmental Lab Accreditation Program, the Vermont Laboratory Accreditation Program, the Massachusetts Laboratory Certification Program and the Maine Laboratory Accreditation Program. For a list of current accredited tests, please visit the websites listed below. Sampling performed by the lab is according to the lab document "Water Sampling Instructions". EPA standards list pH & Chlorine as field parameters which should be tested immediately upon sample collection. Samples tested for pH after submission are beyond the hold time. Samples will be analyzed as quickly as laboratory operations allow. Metals samples may be analyzed the same day they are received. # Sample(s) received at laboratory do not meet method specified temperature criteria.

Solid samples are reported on a dry weight basis unless noted otherwise.

Subcontract Laboratories: SUB2: Nelson Analytical Maine NH2018 SUB 7; Nelson Analytical EAL Div. NH1007; SUBA: NH2073/2239, SUB5: NH2530, SUB8: NH2136, SUB9: NH2557

<http://des.nh.gov/organization/divisions/water/dwgb/nhelap/>
http://healthvermont.gov/enviro/ph_lab/PublicHealthLaboratory.aspx
<https://www.maine.gov/dhhs/mecdc/environmental-health/dwp/professionals/labCert.shtml>
<https://www.mass.gov/certified-laboratories>

